

SEPT 28, 1991

ABENAKI SKI CLUB

PG 3

ROUTES IN SOME CASES PASSING
THROUGH OTHER SLEEPING ROOMS IT
IS RECOMMENDED THAT THESE DETECTORS
ALSO BE TIED INTO THE SYSTEM.

IT IS ALSO REQUIRED THAT THERE
BE A MANUAL ALARM PULL STATION
AT AN OBVIOUS AND EASILY LOCATED
LOCATION ON THE FIRST FLOOR
WHERE THE ALARM CAN BE SOUNDED
MANUALLY.

A SECOND BASIC REQUIREMENT IS FOR
THERE TO BE AT LEAST TWO ROUTES
OF ESCAPE FROM EACH FLOOR.

THE GROUND FLOOR HAS A FRONT
DOOR AND A SIDE DOOR.

THE SECOND FLOOR HAS A FRONT
STAIR AND A BACK STAIR. FOR THESE
STAIRS TO COMPLIMENT EACH OTHER
IN PROVIDING TWO SEPARATE ROUTES
IT IS NECESSARY FOR OCCUPANTS
TO TRAVEL THROUGH INTERVENING
SLEEPING ROOMS. THIS IS ALLOWED
ONLY IF NONE OF THE DOORS ENROUTE
ARE OR CAN BE LOCKED. BEDS AND/OR
FURNITURE MUST BE CLEAR OF ANY
OF THESE DOORS AND A CLEAR
PASSAGE WAY PROVIDED THROUGH
THESE ROOMS. THE ROUTES OF ESCAPE
SHOULD BE MARKED WITH EXIT
SIGNS AND EMERGENCY LIGHTING
PROVIDED SINCE THESE ROUTES
COULD BE VERY CONFUSING IN THE
DARK OR UNDER SMOKE CONDITIONS.

THE ENTRYWAY FOR THE FIRST FLOOR
SIDE DOOR MUST BE KEPT CLEAR OF
ANY ITEMS WHICH WOULD OBSTRUCT
CLEAR PASSAGE.